



City of Ashtabula

Ashtabula City Council

Public Works / Public Utilities / Cable / Schools Committee Meeting

Tuesday, January 27, 2026 at 8:30 AM

Council Chambers

4230 Lake Avenue, Ashtabula, OH 44004

Agenda

- 1. Opening of Committee Meeting**
 - a. Call to Order
 - b. Roll Call
 - c. Sunshine Law Certification
- 2. Welcome and Acknowledgement of Visitors**
- 3. City Manager's Report**
- 4. Water Pollution Control Report**
 - a. WPC Report
- 5. Public Works Report**
- 6. New Business**
- 7. Next Meeting**
 - a. February 24, 2026
- 8. Adjournment**

Water Pollution Control Update

Plant Operations

- **Headworks**
 - Influent pH controller – Failed and replacement has been ordered.
- **Outfall Relocation**
 - Effluent 002 flow meter is installed and being reported.
 - Mixing zone study proposal received from Amendola Engineering. Under review with the Solicitor's office.
- **Disinfection**
 -
- **Preventative Maintenance (PM)**
 - Primary settling tank #3 sludge withdrawal valve replacement needed this year.
- **Digesters**
 - Digester #1 recirculation pump failure. Impeller and pump casing is in need of replacement. Rotated to #3 digester. Working on obtaining pricing for a replacement.
- **Generator**
 -

Collection System

- **Tivision**
 - Replacement pump ordered for pump station.

Miscellaneous Updates

- **Vehicles**
 - 2002 International Dump – motor failure. Replacement truck budgeted for 2026.
- **Industrial Pretreatment**
 - Technical Justification – Drafted and reviewed.
- **Tours**
 - 02/17/2026 – Career Day – Ridgeview Elementary
 - 02/20/2026 – Leadership Tour at the Plant.
- **Safety**
 - Confined space training scheduled for 04/23/2026
- **Annual Reports- in the process of completing**
 - Mercury Pollutant Minimization Program update
 - Annual Pretreatment Report
 - Annual SSO Report
 - Annual Air Permit Report
 - Annual Sewage Sludge Report (submitted)