



City of Ashtabula

Ashtabula City Council

Public Works / Public Utilities / Cable / Schools Committee Meeting

Tuesday, June 23, 2026 at 8:30 AM

Council Chambers

4230 Lake Avenue, Ashtabula, OH 44004

Agenda

- 1. Opening of Committee Meeting**
 - a. Call to Order
 - b. Roll Call
 - c. Sunshine Law Certification
- 2. Welcome and Acknowledgement of Visitors**
- 3. Special Guest Presentation**
 - a. Lisa Newsome, Superintendent Ashtabula Area City Schools
- 4. City Manager's Report**
- 5. Water Pollution Control Report**
 - a. WPC Report
- 6. Public Works Report**
- 7. New Business**
- 8. Next Meeting**
 - a. July 28, 2026
- 9. Adjournment**

Water Pollution Control Update

Plant Operations

- **Headworks**
 - Influent pH probe failure. Replacement ordered.
- **Outfall Relocation**
 - Completed first seasonal mixing zone study 5/18 – 5/27. Amendola Engineering is currently working on the preliminary draft report for OEPA review.
- **Disinfection**
 - UV system is online and operational.
- **Preventative Maintenance (PM)**
 - Primary settling tanks 1 – 3 completed.
- **Digesters**
 - East heat exchanger blower sent out for repair and rebuild.
 - East heat exchanger hot water recirculation pump to be replaced.
- **Laboratory**
 - Plant toxicity testing scheduled for 6/15 -6/19, in conjunction with priority pollutant testing.

Collection System

- **Pump Stations**
 - EQ Basin check valve failure on pump #2.

Miscellaneous Updates

- **Vehicles**
 - 1999 Freightliner - replaced rear suspension equalizer beams.
 - 2016 F-150 - frame repair and brakes replaced.
 - 2006 Econoline Van - heli-coil and fuel pressure sensor installed.
- **Capital Improvement Plan**
 - Continued meetings with GPD regarding CIP for the plant. Electrical, Mechanical, and HVAC.
- **Waste Management**
 - Profile 492812OH is being renewed for grit disposal.
- **Public Outreach**
 - 5/27 – Career Day Ridgeview Elementary
 - 5/29 – Career Day Kingsville Elementary
- **Sewer Camera**
 - Main line crawler is at MTech for repairs.